



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

**DATE:** 11.09.2015

**TO:** ProTrak

**FROM:** Bill McDow  
Transportation Planning

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

---

■ **DREAMS PARKING LOT [TRC Plan Review #2]**

**TECHNICAL STANDARDS – PARKING:**

1. The parking spaces adjacent to the Bio-retention area to be less than 18' in length. Regular spaces are a minimum of 8.5' by 18' and compact spaces are a minimum of 8' by 16'. Please ensure the parking spaces at the Bio-retention area meet this standard.
2. As previously stated, please show location of handicap ramp(s) and signs and provide details on the plan.
3. Include appropriate City of Wilmington approval stamps prior to submitting final plans.
4. No Further Comments.